



Building Permit No. \_\_\_\_\_

Date Received \_\_\_\_\_

**FIRE SPRINKLER AFFIDAVIT FOR ALTERATIONS OR TENANT IMPROVEMENTS  
(1 to 10 sprinkler heads without plans)**

(Submittal of form by fax or at over-the-counter times; 8am – 4pm)

<b>Project Name:</b> _____	<b>Occupancy:</b> _____
<b>Job Address:</b> _____	<b>Type of Construction:</b> _____
<b>Suite:</b> _____	
<b>Contractor:</b> _____	<b>Phone:</b> _____
<b>Number of proposed or altered heads:</b> _____	
<b>Type: WET      Hazard: LIGHT      Density: .10gpm</b>	

I, \_\_\_\_\_, Oregon Construction Contractors Board No. \_\_\_\_\_ certify that the following is true and reasonably defines the scope of work for this project:

- a) All work is limited to drops and armovers in a light-hazard occupancy with like sprinkler heads, i.e standard response and quick response.
- b) Positions of sprinkler heads relative to architectural features such as soffits, beams, partitions, walls, etc. complies with the current adopted edition of NFPA 13.
- c) The proposed work does not require hydraulic calculations because sprinklers use standard spacing and are not extended coverage or other specialized type of sprinkler.
- d) Only one sprinkler head will be installed from one drop (exception: up to two heads from one drop may be installed when each head is in a separate fire area).
- e) The area covered per sprinkler head is limited to the spacing requirements of NFPA 13.
- f) Tenant improvements in a new building shall be equipped with Quick Response heads (see 2002 NFPA 13, Section 8.3.3.1)
- g) The installation shall comply with the requirements of the current adopted edition of NFPA 13.
- h) Piping shall not be concealed until hangers and bracing are inspected.
- i) Final approval shall be subject to onsite tests and inspections.

In addition, I understand the following is required:

- A sketch attached to this document showing the area of work within the building’s structure, and a copy of this document shall be available for all inspections.

Signature: \_\_\_\_\_

Date: \_\_\_\_\_