



Memorandum

To: Water Department Engineering and Distribution
CC: File
From: Bernie Monahan
Date: October 18, 2005
Re: Approved Product Notice – CLOW Medallion Fire Hydrant

Clow Medallion Fire Hydrants, as manufactured in accordance with AWWA Standard C502, UL listed and FM approved, and in compliance with applicable provisions of the 2005 Water Department Engineering & Construction Standards, are approved for use in the City of Hillsboro Water System.